



# CERTIFICATE

|                           |   |
|---------------------------|---|
| <b>Certificate holder</b> | <b>Techem Energy Services GmbH</b><br><b>Hauptstr. 89</b><br><b>65760 Eschborn</b><br><b>GERMANY</b>  |
| <b>Product</b>            | Heat cost allocators - Appliances with electrical energy supply   |
| <b>Type, Model</b>        | FHKV radio 4 / EHKV vario 4   |
| <b>Testing basis</b>      | DIN EN 834:2013-12<br>Certification scheme Heat cost allocators (2014-08)   |
| <b>Mark of conformity</b> |    |
| <b>Registration No.</b>   | 295/15 E  |
| <b>Valid until</b>        | 2021-01-31  |
| <b>Right of use</b>       | This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.<br><br>See annex for further information. |

2016-02-04

  
Dipl.-Phys. Carlo Seiser  
Certifier

# ANNEX

Page 1 of 1

|  |   |
|--|---|
| <b>Certificate</b>                             | 295/15 E dated 2016-02-04   |
| <b>Technical Data</b>                          | Type: Compact and remote sensor version<br>Readout of measured values: decentral<br>Basic conditions: 50 °C<br>Upper temperature limits stated t(max): 90 °C Compact device, 130 °C Remote sensor device<br>Lower temperature limits stated t(min): 35 °C |
| <b>Testing laboratory/<br/>Inspection body</b> | Universität Stuttgart<br>Institut für GebäudeEnergetik<br>Pfaffenwaldring 35<br>70569 Stuttgart<br>GERMANY  |
| <b>Test report(s)</b>                          | SD15 H001 TE dated 2015-06-26<br>SD15 H001 TE K.1 dated 2016-01-15  |

